



Drinking-Water System Number: 260002824
Drinking-Water System Name: Maryhill Distribution System
Drinking-Water System Owner: Township of Woolwich
Drinking-Water System Category: Large Municipal Residential
Period being reported: January 1, 2024 – December 31, 2024

For Large Municipal Residential Systems:

Does your Drinking-Water System serve more than 10,000 people?

- Yes
- No

Is your annual report available to the public at no charge on a website on the internet?

- Yes
- No

Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection:

- Available by calling Infrastructure Services at 519-669-6041
- www.woolwich.ca

Are there any Designated Facilities serviced by your system, and is a copy of your annual report provided to all Facilities?

No.

1. List all Drinking-Water Systems (if any), which receive all their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
None	N/A

2. Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all its drinking water?

- Yes
- No

3. Indicate how you notified system users that your annual report is available and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request

4. Describe your Drinking-Water System

The Maryhill distribution system is standalone and is not treated by the Township of Woolwich, therefore, there is no chlorine boosting, ultraviolet (UV) irradiation, secondary disinfection, or pressure boosting or pressure control within the control of the water distribution system. The Township of Woolwich does not own or operate the water storage facilities servicing this system.

The Maryhill Distribution System receives water from the Maryhill Well Supply System. The Maryhill Well Supply System is owned and operated by the Region of Waterloo.



The Township of Woolwich owns and operates the Maryhill distribution system, including pipes, valves, and residential meters. The distribution system serves approximately 164 residential service connections with a population of approximately 378 people. The Maryhill Distribution System does not serve any industrial properties. There are five hydrants located on the system.

5. List all water treatment chemicals used over this reporting period.

Water treatment is the responsibility of the Region of Waterloo. The Region of Waterloo reports all the treatment chemicals used via their annual Water Quality Reports. The Township of Woolwich disinfects all parts, material and pipe during new installation and repair.

6. Were any significant expenses incurred?

- Install required equipment.
 Repair required equipment.
 Replace required equipment.

7. Please provide a brief description and a breakdown of the monetary expenses incurred.

8. Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Table with 6 columns: Incident Date, Parameter, Result, Unit of Measure, Corrective Action, Corrective Action Date. Row 1: June 19, 2024, Total Coliform, Present (P), A - P, The adverse and upstream sites were flushed and sampled, June 20, 2024

9. Microbiological testing is done under Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

Table with 6 columns: Sample Source, Number of Samples, Range of E. Coli or Fecal Results (min) - (max), Range of Total Coliform Results (min) - (max), Number of HPC Samples, Range of HPC Results (min) - (max). Row 1: Distribution, 157, A, A - P, 81, 0 - >500 (CFU/mL)

10. Operational testing is done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

Table with 4 columns: Parameter, Number of Grab Samples, Range of Results (min) - (max), Unit of Measure. Row 1: Township Chlorine Free, 368, 0.52 - 1.44, mg/L

11. Summary of additional testing and sampling conducted in accordance with the requirement of approval, order, or other legal instrument.

Table with 5 columns: Date of legal instrument issued, Parameter, Date Sampled, Result, Unit of Measure. Row 1: N/A, , , ,

12. Summary of Inorganic parameters evaluated during this reporting period or the most recent sample results.

Table with 5 columns: Parameter, Number of Samples, Result Value Range (min-max), Unit of Measure, Number of Exceedances. Rows: Alkalinity (4, 312 - 354, mg/L, None), pH (4, 7.61 - 8.74, pH, None)



13. Summary of lead testing under Schedule 15.1 during this reporting period:

Location Type	Number of Samples	Range of Lead Results (min) – (max)	Unit of Measure	Number of Exceedances
Plumbing	Not Required		ug/L	None
Distribution	4	<0.200	ug/L	None

14. Summary of Organic parameters sampled during this reporting period or the most recent sample results.

Parameter	Number of Samples	Result Value	Unit of Measure	Number of Exceedances
Haloacetic Acids (HAA) (NOTE: annual average)	9	<7.68	ug/L	None
THM (NOTE: annual average)	9	27.23	ug/L	None

15. List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
N/A			